



CERTIFICATE OF ACCREDITATION

The ANSI National Accreditation Board

Hereby attests that

Command LLC
6139 Silverglade Drive
Columbus, OH 43230

Fulfills the requirements of

ISO/IEC 17020:2012

In the field of

INSPECTION

This certificate is valid only when accompanied by a current scope of accreditation document.
The current scope of accreditation can be verified at www.anab.org.

R. Douglas Leonard Jr., VP, PILR SBU

Expiry Date: 28 September 2023
Certificate Number: AI-3025



An inspection body's fulfilment of the requirements of ISO/IEC 17020:2012 means the inspection body meets both the technical competence requirements and management system requirements that are necessary for it to consistently deliver technically valid inspection results (refer to joint ISO-ILAC-IAF Communiqué dated Sept 2013).

SCOPE OF ACCREDITATION TO ISO/IEC 17020:2012

Command LLC
6139 Silverglade Drive
Columbus, OH 43230

Cody Stallter
Phone: (614) 398-0120 / cody@commandtesting.com

INSPECTION TYPE A (FIRST PARTY) BODY

Valid to: **September 28, 2023**

Certificate Number: **AI-3025**

Mechanical

Items, Materials OR Products Inspected	Type and Range of Inspection	Methods and Procedures
Inspections of Aerial Fire Apparatus	Aerial Devices Testing at clients location covering the following parameters: Drift, Visual, Bolts, Functional Test, Operational Test on Aerial Ladders, Operational Test on Elevating Platforms, Water System, and Load Tests	NFPA 1901 Chapter 19; NFPA 1911 Chapter 22; FA-0001
Inspection of Fire Apparatus Pumps	Pump Testing at clients location covering the following parameters: Flow (GPM), Discharge Pressure (PSIG), Suction Allowance (PSIG), Net Pump Pressure (PSI), Engine Speed (RPM), Pump Speed (RPM), Gear Ratio Engine to Pump	NFPA 1901 Chapter 16; NFPA 1911 Chapter 21; FP-0001

Note:

1. This scope is formatted as part of a single document including Certificate of Accreditation No. AI-3025.



R. Douglas Leonard Jr., VP, PILR SBU