

# CRPC #700 · INVITATION TO BID FUEL OIL AND DIESEL

PUBLIC AMENDMENT #1: Bid Table Change to Add Meriden & Opportunity Q&A Answers

#### **BID TABLE CHANGE**

NOTICE: Meriden's quantities have been added to the bidtable. Please download the new bid table form.

The bidtable has been changed to include quantities of fuel oil and diesel from Meriden, CT. Site details for Meriden have been uploaded at the end of this document. Vendors will need to download and submit the new version of the bid table on Bonfire in order for their submission to be complete. Vendors will also be asked to confirm receipt of this addendum.

#### **OPPORTUNITY Q&A ANSWERS**

Would it be possible to receive the tabulations from the previous bid? Thank you!

All tabulations from the previous bid are publicly available on https://crcog.org/capitol-region-purchasing-council/annual-bid-results/, under the expanding tab "Bid Results prior to 7/1/2019."

Our records indicate that Bloomfield has a 2,000 gallon diesel tank. However, appendix A indicates this tank is a 10,000 gallon. Please advise which is correct.

This tank will be a 10,000 gallon tank by the time the new contract period starts.

For the Enfield at 40 Moody Road what is the difference between the two 60,000 quantities? Is this for summer and winter diesel? Does the location get a total of 120,000 gallons per year?

The Enfield 40 Moody Road complex has two 10,000 gallon tanks, each of which will have 60,000 gallons of fuel. So yes, the location will get a total of 120,000 gallons a year of ULSD, split between the two tanks.

### Could you please send the specifications you need for the premium diesel fuel?

Premium diesel fuel specifications: premium diesel fuel shall be hydrocarbon oil, free from acid, grit, salt water and fibrous or other foreign matter, and shall conform to the requirements of ASTM D975 of latest revision.

#### If we were to include any clauses with our NYMEX adder would they be considered

Each town or entity makes its own award and would consider any added clauses individually. Added clauses should be uploaded separately under optional documents and clearly noted with your bid.

## Have any addendums been released for this fuel bid?

One addendum will be released along with this opportunity Q&A adding Meriden's quantities to the bid.

# Could you please review the below indemnity language and see if this would be acceptable?

Each town will make its own award to a contractor and may or may not feel that the presented indemnity language may be acceptable to them on an individual basis. If you would like to make the proposed indemnity language a part of your bid, please upload it as a separate document under optional documents.

#### CRPC Bid #700 - Fuel Oil and Diesel

Site Details Report

	SITE DETAILS					Enter THIS COMING YEAR'S Request Here		
Town	Oil Type	Location/Address	Special Notes (site conditions, delivery notes, other conditions, etc.)	Tank Size (in Gallons)	ls Tank Temporary?	ENTER THIS YEAR'S REQUEST by Gallons Requested per Tank	THIS YEAR'S REQUEST TOTAL Gallons by Fuel Type	ADDITIONAL NOTES 8 CHANGES
Meriden	#2 Oil	Water 117 Parker Ave				1,500		
		Water Elmere Plant Chamberlain Hwy				2,000		
		Water Merimere Plant Reservoir Ave				3,000		
		Water Bradley/Hubbard Plant 800 Westfield Rd				3,500		
		Water 1285 South Meriden Rd				100		
		Golf 688 Westfield Rd				1,500		
		Golf 688 Westfield Rd				500		
		Barry School 124 Columbia Ave		10,000		28,000		
		Hooker School 70 Overlook St		10,000		10,000		
		Pulaski School 100 Clearview St		10,000		19,000		
		Franklin School 426 West Main St				1,000		
		Misc				9,400	79,500	
	Clear Diesel	Public Works Evansville Ave				12,500		
		BOE Maintenance 998 N. Colony Rd		275		1,000		
		Garage 55 Michael Dr				40,000		
		Golf 688 Westfield Rd				2,000		
		WPCF Harbor Brook				12,500		
		WPCF Chlorine				750		
		WPCF Cedarwood Dr				750		
		Police South Grove St				100		
		WPCF Blower Building				750	70,350	
	Dyed Diesel	Fire 561 Broad St				250		
		Lincoln School 164 Centennial Ave		400		100		
		Misc				2,600	2,950	